

RICK SNYDER GOVERNOR

# DEPARTMENT OF LICENSING AND REGULATORY AFFAIRS LANSING

SHELLY EDGERTON DIRECTOR

#### BUREAU OF CONSTRUCTION CODES

# CERTIFICATE OF ACCEPTABILITY PRODUCT APPROVAL

#### 1657-PA

Issued by the Michigan State Construction Code Commission in accordance with authority granted under Section 21, 1972 P.A. 230, MCL 125.1521 on the recommendation of the Bureau of Construction Codes, Plumbing Division. This product was reviewed to the 2012 Michigan Plumbing Code.

#### **MANUFACTURER:**

Green Drain Inc

#### PRODUCT:

One Way Drain Trap Seal model numbers GD 102, GD 103, GD 103.5 and GD 104

#### MANUFACTURER DESIGNATION:

15275 Collier Blvd. 201-262 Naples, FL 34119

### CONDITIONS OF USE AND INSTALLATION:

- 1. All requirements of the Michigan Plumbing Code shall be acceptable.
- 2. Shall be installed in accordance with the manufacturer's installation instructions.
- 3. These devices shall not replace the need for a trap.
- 4. These devices are approved to take the place of a trap seal primer valve
- 5. This approval shall become void if and when the product no longer meets the requirements of the Michigan Plumbing Code.

## THIS CERTIFICATE SHALL NOT BE USED FOR ADVERTISING PURPOSES.

Effective Date: July 27, 2015

Providing for Michigan's Safety in the Built Environment